







LEGENDA	
SIMBOL	SPECIFICATIE TEHNICA
 Hidrant  Furtun plat tip C (Ø21)  L furtun: 20[m]  Racord DN 50	Hidrant interior de incendiu Dn50, montat in cutie ingropata in grosimea peretelui, cu rama si geam dimensiuni 500x500x140; tambur echipat cu furtun plat cu racorduri legate (20ml), robinet hidrant tip C cu racord fix din aluminiu montat, teava de refulare tip "C" cu robinet (caneal) si cheie racord ABC, (SR EN 671-2/2002)
	Teava din otel zincat Dn 2"
	Coloana din otel zincat Dn 2"
RH...	Raza de actiune a hidrantului

Specificatie	Numele	Semnatura	Cerinta	Referat nr./data	
Verificator				Referat de verificare .....	
Expert tehnic				Referat expertiza .....	
S. C. BAL DESIGN GROUP S. R. L.				BENEFICIAR : UNIVERSITATEA TEHNICA "GHEORGHE ASACHI" IASI FACULTATEA DE INGINERIE ELECTRICA, ENERGETICA SI INFORMATICA APLICATA	Proiect nr. 80/2022
Specificatie	Numele	Semnatura	Scara	Proiect : LUCRARI DE REABILITARE, MODERNIZARE SI CRESTERE A EFICIENTEI ENERGETICE IMOBIL ETN	
Sef Proiect	arh. Daniela Scripcariu		1:100	D.A.L.I.	
Proiectat	ing. Colacu G.		Format A1	INSTALATII DE LIMITARE SI STINGERE A INCENDIILOR	
Desenat	ing. Paulet Narcis		DATA 2022	PLAN ETAJ 3 INSTALATII HIDRANTI	
					Planşa nr. H.05